



CERTIFICATE

No. B 16 05 95562 001

Annex : Model details

Type	Rated voltage (V)	Rated current (A)	Rated cross section(mm ²)	Rated insulation voltage (V)
JUT1-1.5	500	17.5	1.5	500
JUT1-2.5	800	24	2.5	800
JUT1-4	800	32	4	800
JUT1-6	800	41	6	800
JUT1-10	800	57	10	800
JUT1-16	800	76	16	800
JUT1-35	1000	125	35	1000
JUT1-2.5B	690	24	2.5	690
JUT1-2.5E	500	24	2.5	500
JUT1-2.5/2	500	24	2.5	500
JUT1-2.5/2L	500	24	2.5	500
JUT1-2.5/2Q	500	24	2.5	500
JUT1-4E	500	32	4	500
JUT1-4K	800	32	4	800
JUT1-4/2	500	32	4	500
JUT1-4/2L	500	32	4	500
JUT1-4/2Q	500	32	4	500
JUT1-4/2-2	690	32	4	690
JUT1-4/1-2	500	32	4	500
JUT1-4/2-2K	690	32	4	690
JUT1-6S	400	41	6	400
JUT1-35B	800	125	35	800
JUT2-2.5	800	24	2.5	800
JUT2-4	800	32	4	800
JUT2-6	800	41	6	800
JUT2-10	800	57	10	800
JUT2-16	800	76	16	800
JUT2-35	800	125	35	800
JUT2-70	800	192	70	800
JUT2-2.5E	380	24	2.5	380
JUT2-4K	250	32	4	250
JUT2-4/2	500	32	4	500
JUT2-4/2L	500	32	4	500
JUT2-6S1	500	41	6	500
JUT3-1.5	500	17.5	1.5	500
JUT3-2.5	800	24	2.5	800
JUT3-4	800	32	4	800

CERTIFICATE

No. B 16 05 95562 001



Product Service

Type explanation:

JUT X - XX XXX / XXXX
(1) (2) (3) (4) (5)

(1): Series number

(2): Application

- 1: intended for industrial use, screw type connection
- 2: intended for industrial use, screw type connection
- 3: intended for industrial use, screwless type connection

(3): Wire capacity:

- 1.5: 1.5 mm²
- 2.5: 2.5 mm²
- 4: 4 mm²
- 6: 6 mm²
- 10: 10 mm²
- 16: 16 mm²
- 35: 35 mm²
- 70: 70 mm²

(4): Construction type

- Blank: General type
- B: Building installation type
- K: Switch type
- S: Testing hole type
- S1: Testing hole type, different construction
- E: MINI screw type
- F: Mini spring type
- W: Wago spring type

(5): Connect opening feature

- Blank: one in and one out
- 2: two separated layer, four connection
- 2L: two connected layer, four connection
- 2Q: two separated layer, four connection, with bridge connection
- 2-2: two in and two out, four connection
- 2-2K: two in and two out, four connection, Switch type
- 1-2: three wire, on in and two out